

DEWEY BEACH WATER DISTRICT TEST RESULTS FOR CONSUMER CONFIDENCE REPORT - 2008

Microbiological	Max. Level Detected			MCL	MCLG	Typical source of contaminant
	Violation	and/or Range				
Total Coliform Bacteria	N	0		one positive	0	Naturally present in the environment
Inorganic Chemicals	Violation	Level				
	Detected	Measurement	Unit	MCL	MCLG	Typical source of contaminant
Copper (see note 1)	N	0.063	ppm	AL=1.3	1.3	Corrosion of household plumbing systems
Lead (see note 1)	N	0.0045	ppm	AL=15	0	Corrosion of household plumbing systems
Nitrate* (sampled 6/5/08)	N	8.4	ppm	10	10	Runoff from fertilizer use
Fluoride (sampled 6/5/08)	N	<0.1	ppm	4	4	Water additive which promotes strong teeth
Unregulated Inorganic Contaminants						
	Violation	Level				
	Detected	Measurement	Unit	MCL	MCLG	
Alkalinity	N	18	ppm			
Chloride	N	25.4	ppm	250		
Hardness	N	8.6	ppm			
Iron	N	0.08	ppm	0.3	0	
PH	N	7.8	std. units	6.5-8.5		
Sodium	N	23.8	ppm		0	
Total Dissolved Solids	N	140	ppm	500		
Organic Chemicals						
	Violation	Level				
	Detected	Measurement	Unit	MCL	MCLG	Typical source of contaminant
Total Trihalomethanes (TTHM)	N	1.25	ppb	80	NA	By-product of drinking water chlorination.
*Nitrate: Nitrate in drinking water at levels above 10 mg/l is a health risk for infants of less than six months of age. High nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.						
Note 1: The listed lead and copper concentrations are the 90 th percentile value from samples collected July 24, 2008.						
If you have any questions about this report or concerning our water utility, please contact Heather Sheridan at (302) 855-7730.						