



ELECTRICAL CABINET - POWER SIDE

NOTES



1. METER & BASE (MOUNT ON POWER CABINET).
2. WIREWAY 6" WITH POWER TERMINAL BLOCKS, UL RATED.
3. SINGLE PHASE MONITOR.
4. 125V, 20A, GFCI RECEPTACLE AND LIGHT SWITCH.
5. JUNCTION BOX NEMA 4 ENCLOSURE.
6. WETWELL FAN MOTOR CONTROLLER.
7. MANUAL 20A-120V SWITCH (FOR EXTERIOR SITE LIGHT MANUAL CONTROL).
8. INTERIOR LIGHT FIXTURE.



SUSSEX COUNTY
ENGINEERING DEPARTMENT

APPROVED: *[Signature]*
SUSSEX COUNTY ENGINEER

TIER 2 PUMP STATION:
TYPICAL ELECTRICAL
CABINET POWER SIDE

DETAIL
E-10

LAST REVISED:
DEC 2021