



NOTES

1. POLE SHALL BE ALUMINUM ROUND TAPERED, BLACK FINISH, 12' HEIGHT, 3" PIPE FITTER, WITH ANCHOR BOLTED BASE.
2. LIGHT TO BE LOCATED TO PROVIDE DIRECT ILLUMINANCE OF WET WELL AREA.
3. LIGHT FIXTURE TO BE RATED TO PROVIDE A MIN OF 10,000 LUMENS AT 5,000 K.
4. ORIENTATION OF HINGE SHALL BE COORDINATED WITH LOCATION OF OTHER ABOVE GROUND FEATURES WITHIN PUMP STATION SITE.



SUSSEX COUNTY
ENGINEERING DEPARTMENT

APPROVED: *James Chedoke*
SUSSEX COUNTY ENGINEER

SITE LIGHT

DETAIL
E-2

LAST REVISED:
DEC 2021