



NOTES

1. TRENCH DETAIL IS APPLICABLE TO PUMP STATION SITES ONLY.
2. TRENCH WIDTH SHALL BE OUTSIDE DIAMETER OF CONDUIT PLUS 6 INCHES ON EITHER SIDE.
3. FOR MULTIPLE CONDUIT CONFIGURATIONS, PROVIDE 3" SEPARATION BETWEEN CONDUITS.



SUSSEX COUNTY
ENGINEERING DEPARTMENT

APPROVED: *[Signature]*
SUSSEX COUNTY ENGINEER

UNDERGROUND
CONDUIT
INSTALLATION

DETAIL
E-5

LAST REVISED:
DEC 2021