



**ELECTRICAL CABINET - CONTROLS SIDE**

**NOTES**



1. RRT
2. COMBINATION NEMA 1 MOTOR STARTER
3. MINI CAS II
4. JUNCTION BOX NEMA 4 ENCLOSURE
5. UPS
6. THERMOSTAT
7. 125V, 20A, GFCI RECEPTACLE AND LIGHT SWITCH
8. CABINET HEATER
9. INTERIOR LIGHT FIXTURE



SUSSEX COUNTY  
ENGINEERING DEPARTMENT

APPROVED: *[Signature]*  
SUSSEX COUNTY ENGINEER

TIER 2 PUMP STATION:  
TYPICAL ELECTRICAL  
CABINET CONTROL SIDE

DETAIL  
E-9

LAST REVISED:  
DEC 2021