



**NOTES:**

1. CONSTRUCTION: NEMA 3R (MODIFIED NEMA 12).
  - A. ENCLOSURE/DOORS/DRIP SHIELDS: ALUMINUM.
  - B. SUB PANEL: ALUMINUM.
  - C. PADLOCKING HANDLE: L36 STAINLESS STEEL.
  - D. CHANNEL (ON BOTTOM OF ENCLOSURE): ALUMINUM, 1.50"H x 3.00"W.
  - E. DOOR STOPS: ON BOTTOM OF EACH DOOR.
2. FINISH:
  - A. ENCLOSURE/DOORS/DRIP SHIELDS: S-102 ALMOND PAINT.
  - B. SUB PANEL: WHITE PAINT.
3. ANTENNA SHALL BE PANORAMA LPAM-BC3G-26-3SP WITH COMPATIBLE MOUNTING BRACKET.

ENGRAVING CHART				
REF.	NAME PLATE SIZE (W x H)	TEXT HEIGHT	LINE	TEXT
NP-01	8" x 2"	1/2"	L1	[NAME] PUMP STATION
			L2	POWER EQUIPMENT CABINET
NP-02	8" x 2"	1/2"	L1	[NAME] PUMP STATION
			L2	CONTROL EQUIPMENT CABINET

**NOTES:**  
 1. NAMEPLATES: WHITE LAMICOID (2-PLY) WITH BLACK ENGRAVED LETTERS.  
 2. ATTACH WITH S.S. DRIVE SCREWS (COAT REAR OF SCREW WITH SILICON SEAL).



SUSSEX COUNTY ENGINEERING DEPARTMENT

APPROVED: *[Signature]*  
 SUSSEX COUNTY ENGINEER

POWER AND CONTROL CABINET ARRANGEMENT  
 SINGLE PHASE SERVICE

DETAIL

I-5

LAST REVISED:

4/25/2023