



NOTES:

1. STEPS SHALL BE ORIENTED OVER BENCH AND NOT FLOW CHANNEL. BOTTOM STEP SHALL BE 12" MAX. FROM TOP OF BENCH.
2. EMBEDMENT LENGTH OF REBAR SHALL BE SUITABLE FOR 5" MIN. WALL THICKNESS.



SUSSEX COUNTY
ENGINEERING DEPARTMENT

APPROVED: *[Signature]*
SUSSEX COUNTY ENGINEER

MANHOLE STEP

DETAIL
S-1.09

DATE ISSUED:
12/30/2021