



NOTES:

1. CLEANOUT SHALL NOT TO BE LOCATED WITHIN LIMITS OF DITCH, SWALE, ETC.
2. MAINTAIN 10' MIN. SEPARATION BETWEEN SEWER AND WATER LINES.
3. MINIMUM DEPTH OF SEWER LATERAL AT ANY POINT INCLUDING UNDER DITCHES, SWALES, ETC. SHALL BE 30 INCHES. NOMINAL DEPTH SHALL BE AS NOTED ABOVE.
4. SIZE OF PVC LATERAL STUB TO MATCH LATERAL SIZE.
5. PROVIDE BETWEEN 3" AND 6" OF CLEARANCE BETWEEN CLEANOUT COVER AND CLEANOUT TOP.
6. ALL CLEANOUT DEPTHS LABELED AS CRITICAL DEPTH LATERALS SHALL BE INSTALLED PER CONFIGURATION ON DETAIL S-2.05.
7. METALLIC DETECTABLE REINFORCED UNDERGROUND MARKING TAPE TO BE PLACED WITHIN ENTIRE LIMITS OF SEWER LATERAL TRENCH - REFER TO DETAIL S-3.01 FOR CONFIGURATION.



SUSSEX COUNTY
ENGINEERING DEPARTMENT

APPROVED: *[Signature]*
SUSSEX COUNTY ENGINEER

SEWER LATERAL
CLEANOUT

DETAIL
S-2.01

LAST REVISED:
10/11/2023