



FRAME AND COVER SECTION

NOTES:

1. FRAME AND COVER ASSEMBLY SHALL BE CENTERED OVER THE CLEANOUT RISER.
2. HDPE COMPOSITE SUPPORT RING BASE MAY BE SUBSTITUTED FOR CONCRETE RING IN NON-TRAFFIC AREA. HDPE SUPPORT RING IS NOT PERMITTED IN TRAFFIC BEARING AREA.
3. CLEANOUT FRAME AND COVER SHALL BE INSTALLED BY UTILITY CONTRACTOR PRIOR TO SUBSTANTIAL COMPLETION INSPECTION FOR DEVELOPMENT PROJECTS.
4. MATERIAL FOR FRAME AND COVER SHALL BE HEAVY DUTY GRAY IRON CL35B MEETING THE REQUIREMENTS OF ASTM A48.
5. CLEANOUT COVER SHALL HAVE A RAISED DIAMOND PATTERN WITH A 2" MIN. RAISED "S" IMPRINTED IN SHARP FACE GOTHIC AT CENTER OF COVER. A SINGLE 1" MIN. WIDE PICKHOLE SHALL BE PROVIDED AT EDGE.
6. SEWER CLEANOUT COVERS LOCATED WITHIN A PEDESTRIAN WALKWAY MUST BE ADA COMPLIANT.
7. REFER TO CURRENT DELDOT REQUIREMENTS FOR INSTALLATIONS WITHIN DELDOT RIGHT-OF-WAY.



SUSSEX COUNTY  
ENGINEERING DEPARTMENT

APPROVED: *[Signature]*  
SUSSEX COUNTY ENGINEER

8" SEWER LATERAL CLEANOUT  
FRAME AND COVER

DETAIL  
S-2.03

DATE ISSUED:  
5/31/2022