

8" CLEANOUT FRAME, COVER,
AND RING, SEE DETAIL S-2.03

CLEANOUT ADAPTER AND
RECESSED PLUG

8" PVC (SDR-35)

8" MIN. #57 STONE
ALL AROUND FITTING

PLUG OR CAP 8"
GRAVITY STUB FOR
FUTURE EXTENSION

SEE PLANS FOR
SIZE AND MATERIAL
OF GRAVITY MAIN

SDR 26 TEE OR
TEE-WYE BRANCH

NOTES:

1. PROVIDE BETWEEN 3" AND 6" OF CLEARANCE BETWEEN CLEANOUT COVER AND CLEANOUT TOP.
2. ALL INVERTS OF TEE-WYE CONNECTIONS SHALL BE FIELD SURVEYED FOR FINAL AS-BUILTS.
3. TEE INSPECTION PORT SHALL BE REMOVED AT THE TIME OF EXTENSION OF GRAVITY SEWER SYSTEM.



SUSSEX COUNTY
ENGINEERING DEPARTMENT

APPROVED: 
SUSSEX COUNTY ENGINEER

TEE INSPECTION PORT
FOR FUTURE SEWER
EXTENSIONS

DETAIL
S-2.09

DATE ISSUED:
12/30/2021