



NOTES:

1. THIS DETAIL APPLIES TO BOTH GRAVITY AND FORCE MAIN SEWER INSTALLATIONS.
2. #57 STONE IS REQUIRED FOR BEDDING MATERIAL AND INITIAL BACKFILL TO 12" ABOVE THE PIPE CROWN FOR ALL SEWER INSTALLATIONS 12' DEEP AND GREATER. FOR INSTALLATIONS LESS THAN 12' DEEP, INITIAL BACKFILL MATERIAL REQUIREMENTS MAY BE MODIFIED BASED ON FIELD CONDITIONS, AS APPROVED BY THE COUNTY. ABOVE INITIAL BACKFILL, MATERIAL MEETING THE REQUIREMENTS OF TYPE F BORROW PER DELDOT'S SPECIFICATIONS SHALL BE USED.
3. FOR INSTALLATION WITHIN LIMITS OF DELDOT ROADWAY AND/OR RIGHT-OF-WAY, TRENCH CONFIGURATIONS AND BACKFILL MATERIAL SHALL BE IN ACCORDANCE WITH CURRENT DELDOT REQUIREMENTS.



SUSSEX COUNTY
ENGINEERING DEPARTMENT

APPROVED: *[Signature]*
SUSSEX COUNTY ENGINEER

SEWER TRENCH

DETAIL
S-3.01

DATE ISSUED:
12/30/2021