



NOTES:

1. SEWER ENCASEMENT AT UTILITY CROSSING SHALL BE AT LOCATIONS SHOWN ON DESIGN PLANS OR REQUIRED BY THE COUNTY. ENCASEMENT SHALL EXTEND A MINIMUM OF FIVE (5) FEET ON EITHER SIDE OF UTILITY CROSSING, EXCEPT AT WATER MAINS.
2. SEWER ENCASEMENT AT WATER MAIN CROSSINGS SHALL BE A MINIMUM OF TEN (10) FEET IN LENGTH OR AS DIRECTED BY THE COUNTY ENGINEER.
3. THE CROSSING SHALL BE ARRANGED SUCH THAT THE SEWER PIPE JOINTS WILL BE EQUAL DISTANCES AND AS FAR AS POSSIBLE FROM JOINTS OF CROSSING UTILITY PIPE.



SUSSEX COUNTY
ENGINEERING DEPARTMENT

APPROVED: *[Signature]*
SUSSEX COUNTY ENGINEER

SEWER ENCASEMENT

DETAIL
S-3.02

DATE ISSUED:
12/30/2021