



NOTES:

1. IF VALVE IS LOCATED WITHIN PAVEMENT, CONCRETE COLLAR IS NOT REQUIRED. SEE ALSO NOTE 2 ON DETAIL S-1.01.
2. EXTEND TONING WIRE INTO VALVE BOX. SEE DETAIL S-4.07.
3. LID MUST BE ADA COMPLIANT IF LOCATED WITHIN A PEDESTRIAN WALKWAY.



SUSSEX COUNTY  
ENGINEERING DEPARTMENT

APPROVED: *[Signature]*  
SUSSEX COUNTY ENGINEER

SEWER FORCE MAIN  
ISOLATION VALVE

DETAIL  
S-4.06

DATE ISSUED:  
12/30/2021