



ELEVATION

NOTE:

FOR TRANSITIONS BETWEEN HDPE PIPE AND NON-HDPE PIPE, AN APPROPRIATELY DESIGNED CONCRETE THRUST COLLAR AROUND A POLY WALL ANCHOR SHALL BE INCORPORATED TO ACCOUNT FOR THE POISSON EFFECT OF THE HDPE PIPE. AS AN ALTERNATIVE, ADDITIONAL JOINT RESTRAINTS SHALL BE INCORPORATED OUTSIDE THE LIMITS OF HDPE PIPING, AS APPROVED BY THE COUNTY.



SUSSEX COUNTY
ENGINEERING DEPARTMENT

APPROVED: *[Signature]*
SUSSEX COUNTY ENGINEER

TRANSITION FROM HDPE
TO NON-HDPE PIPE

DETAIL
S-4.08

DATE ISSUED:
12/30/2021