



NOTES:

1. ALL ELECTRICAL WORK SHALL BE PERFORMED PER THE NATIONAL ELECTRICAL CODE.
2. REFER TO THE LATEST VERSION OF SUSSEX COUNTY'S "PROCEDURES FOR GRINDER PUMP CONNECTIONS" FOR MINIMUM ELECTRICAL REQUIREMENTS OF POWER SUPPLY.
3. POWER DISCONNECT SWITCH ON HOUSE SIDE OF WOOD POST NOT SHOWN FOR CLARITY. DISCONNECT SWITCH SHALL BE SIEMENS MODEL WN2060U, 240 V. 60A, PULL OUT NON FUSED WITH NEMA 3R ENCLOSURE, OR APPROVED EQUAL.



SUSSEX COUNTY
ENGINEERING DEPARTMENT

APPROVED: *James Chedoke*
SUSSEX COUNTY ENGINEER

**CONTROL PANEL
POST MOUNTING**

DETAIL
S-5.07

DATE ISSUED:
6/26/2023